

**DETROIT HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH & SAFETY  
FIELD INVESTIGATION REPORT**

**RESIDENT/BUSINESS NAME:** RONALD BROWN ACADEMY

**ADDRESS:** 11530 EAST OUTER DRIVE, DETROIT, MI

**COMPLAINANT:** Referral From BSEED

**TYPE OF INVESTIGATION:**

<b>Air Quality</b>	<b>Hazardous Waste</b>	
<b>Environmental</b>	<b>Solid Waste</b>	
✓		

**OTHER:**

**NATURE OF COMPLAINT:** DETROIT PUBLIC SCHOOLS

**NATURE OF COMPLAINT:** Potential health-related violations observed by BSEED inspectors.

Date of Inspection: 1/21/16

**INVESTIGATION SUMMARY:** An environmental health inspection was conducted at Ronald Brown Academy. Representatives from the Detroit Health Department-Environmental Health and Safety assessed the over-all environmental health and safety conditions of this DPS school facility.


**Findings and Recommendations:**

1. Rodent holes and fecal matter are evidence of a possible infestation. Clean and sanitize all areas where fecal matter has been found. Patch all rodent holes to block future. Abate all current infestations. Enforce an integrated pest management system and assure it is being used within 72 hours.
2. Dust and debris were observed in ceiling vents and surrounding areas Clear all dust and debris from ceiling and vents. Inspect HVAC system to assure proper air circulation by a 3<sup>rd</sup> party certified heating and cooling contractor. If repairs are needed, a separate plan of action, including a completion date is requested.
3. Stained ceiling tiles are evidence of a possible roof leak in the main building. Roof will need to be inspected by a 3<sup>rd</sup> party certified roof contractor.to assure it is weather-tight and in sound condition. If repairs are needed, a separate plan of action, including a completion date is requested.
4. Several water fountains were observed in disrepair. Repair all drinking fountains.
5. Failure to conduct the proper repairs within a timely manner will result in a recommendation of facility closure and the revocation of Certificate of Occupancy from the Detroit Health

**CONDUCTED BY:** Detroit Health Department Environmental Health Date: 1/21/16

ROUTINE	Phone COMPLAINT	REFERRAL ✓
---------	-----------------	---------------

Department. Health Department representatives will follow up on vermin infestation within 72 hours, and all other findings within 30 days.



CONDUCTED BY: Detroit Health Department Environmental Health Date: 1/21/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------