

**DETROIT HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH & SAFETY
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: HOLMES ELEMENTRY SCHOOL

ADDRESS: 8950 CRANE, DETROIT, MI 48213

COMPLAINANT: Referral from BSEED

PHONE:

TYPE OF INVESTIGATION:

Air Quality	<u> </u>	Hazardous Waste	<u> </u>
Environmental	<u>✓ </u>	Solid Waste	<u> </u>

OTHER:

NATURE OF COMPLAINT: DETROIT PUBLIC SCHOOLS

DATE: 2/1/16

INVESTIGATION SUMMARY Representatives from the Detroit Health Department-Environmental Health and Safety conducted a full environmental health inspection and assess the air quality, as well as the over-all environmental health and safety conditions of this DPS school facility.

Findings and Recommendations

1. Repair water leak in basement level within 30 days.
2. Repair water damaged ceiling of class rooms and upper level and remove all mold within 72 hours.
3. Provide a roof inspection from a 3rd party certified contractor within 72 hours.
4. Provide an air quality inspection from a 3rd party certified contractor within 72 hours.
5. Repair damaged plaster ceiling in gymnasium with in 30 days.
6. Failure to conduct repairs within a timely manner will result in a recommendation of facility closure and the revocation of Certificate of Occupancy from the Detroit Health Department. Health Department representatives will follow up in 72 hours for roof inspection, mold removal and air quality inspection, and 30 days for other violations.

CONDUCTED BY: City of Detroit Environmental Team **Date:** 2/1/16

ROUTINE	Phone COMPLAINT	REFERRAL ✓
---------	-----------------	---------------



CONDUCTED BY: City of Detroit Environmental Team Date: 2/1/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------