

**DETROIT HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH & SAFETY
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: OSBORN HIGH SCHOOL

ADDRESS: 11600 EAST 7 MILE, DETROIT, MI 48205

COMPLAINANT: Referral from BSEED

TYPE OF INVESTIGATION:

Air Quality	Hazardous Waste
Environmental	Solid Waste
✓	

NATURE OF COMPLAINT: DETROIT PUBLIC SCHOOLS

NATURE OF COMPLAINT: Potential health-related violations observed by BSEED inspectors.

Date of Inspection: 1/21/16

INVESTIGATION SUMMARY: An environmental health inspection was conducted at Osborn High School. Representatives from the Detroit Health Department-Environmental Health and Safety assessed the over-all environmental health and safety conditions of this DPS school facility.

Findings and Recommendations:

1. Several broken windows were found throughout the school. Repair and replace any broken or boarded up windows.
2. A chair was observed being used to lock a broken door. This is prohibited as it is a safety hazard. Please repair broken door within 72 hours.
3. A missing fire extinguisher was observed. Please replace the fire extinguisher within 72 hours.
4. Tiling under the drinking fountains were found in disrepair. All tiles under drinking fountains must properly installed and in good condition.
5. Light bulbs were found burnt out in various parts of the building. Please repair in 72 hours.
6. Missing and stained ceiling tiles show evidence of possible roof leaks and mold infestation. Inspect roof to assure it is weather-tight, remove stains and replace missing and broken ceiling tiles. Repair all water damaged ceiling surfaces. Provide a confirmation of roof inspection from a 3rd party certified roofing contractor. Provide 3rd party air quality inspection. If repairs are needed, supply a separate plan of action for roof and expected date of completion.

CONDUCTED BY: Detroit Health Department Environmental Team **Date:** 1/21/16

ROUTINE	Phone COMPLAINT	REFERRAL ✓
---------	-----------------	---------------

7. Failure to conduct the proper repairs within a timely manner will result in a recommendation of facility closure and the revocation of Certificate of Occupancy from the Detroit Health Department. Health Department representatives will follow up in 72 hours on broken door, fire extinguisher, and light bulbs, and 30 days for all other findings.



CONDUCTED BY: Detroit Health Department Environmental Team Date: 1/21/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------